

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 213

Date: 13.04.24

It is certified that an inspection team headed by BRJ MDHAN SINGH
(ASSISTANT ENGINEER) (Name of Officers
with designation) from P.H-SUB DIVISION NARKATIAGANJ, WEST CHAMPARAN (Name of
Department/Office) inspected the H.S. DAV PUBLIC SCHOOL, NARKATIAGANJ
WEST CHAMPARAN, BIHAR, PIN-845455 (Name & Address of
the School) on _____ and found that the H.S. DAV PUBLIC SCHOOL
NARKATIAGANJ, WEST-CHAMPARAN, BIHAR, PIN-845455 (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal : BRJ MDHAN SINGH

Name : BRJ MDHAN SINGH

Designation : ASSISTANT ENGINEER

To

H.S. DAV PUBLIC SCHOOL

NARKATIAGANJ, WEST

CHAMPARAN, BIHAR PIN-845455

(Name & Address of the Institution)

सहायक अभियंता

ज्यो० स्वी० अवर प्रमण्डल

नरकटिबागंज

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Zone - Muzaffarpur

Division Name: P.H. Division, Bettiah

Format: I

District Name: West Champaran

Sl. No.	Block	Panchayat	Village	Ward No	Population	Name of Habitation	Location of Source	Latitude	Longitude	Parameters															Remarks
										pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
1	Narkatiyaganj	Pakari	Pakari			H.S.D.A.V Public School, Narkatiaganj, West Champaran	H.S.D.A.V Public School, Narkatiaganj, West Champaran			7.4	1	418	248	160	48	9.6	20	170	0.1	5	10	NT	NT	Negative	
Desirable Limit (mg/l)										6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.00	0.01	-	-
Permissible Limit* in absence of alternate source(mg/l)										NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.50	NR	**	-

Analyzed water sample conform to indian standard under permissible limit for drinking purpus

Sample Collected By- Prasant Giri

Vijay Kumar
 Chemist 13/04/2024
 P.H.Division, Bettiah

Agp
 Assistant Engineer
 P.H.Division, Bettiah
 13/04/24
 नमो स्वास्थ्य प्रमोदने
 नरकटियागंज

13.4.24
 Executive Engineer
 P.H. Division Bettiah